



DIVISION OF INDUSTRY SERVICES  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

May 8, 2013

GETINGE GROUP  
GETINGE USA INCORPORATED  
DON SOCHA  
1777 E. HENRIETTA ROAD  
ROCHESTER NY 14624

GETINGE GROUP  
GETINGE DISINFECTION AB  
JENNY SAHLSTROM-NILSSON  
LJUNGADALSGATAN 11  
PO BOX 1505  
VAXJO SE 35115

Re: Description: HEALTH CARE PLUMBING APPLIANCE  
Manufacturer: GETINGE GROUP  
Product Name: 9100 SERIES AND GEW SERIES  
Model Number(s): 9120, 9122, 9125, 9128, GEW 112222, GEW 102020, GEW 102025 AND GEW 102028  
Product File No: 20130131

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes. The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2018.

This approval is contingent upon compliance with the following stipulation(s):

- The water supply piping serving these devices must conform to the materials, sizing, materials and installation requirements of s. SPS 382.40.
- All water supply connections (i.e. hot, cold and high purity) to these devices shall be individually protected by one of the following methods of cross connection control:
  1. an air gap that conforms to ASME A112.1.2; or
  2. a reduced pressure principle (RPZ) backflow preventer that conforms to ASSE 1013. A RPZ installed on a high purity water line shall be comprised of series 316 stainless steel or above.
- All cross connection control methods/devices must be installed in accordance with s. SPS 382.41 (5).
- All cross connection control assemblies shall be registered with this department in accordance with s. SPS 382.20 (1) (c).
- The drain piping serving these devices must conform to the materials, sizing, materials and installation requirements of s. SPS 382.30.

The department is in no way endorsing these products or any advertising, and is not responsible for any situation which may result from their use.

Sincerely,

Glen W. Schlueter  
Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 266-2602 Fax  
glen.schlueter@wi.gov E-mail